



NOTE: REFER TO CONCRETE AS. 2876-2000
CONCRETE KERBS AND CHANNELS

ALL KERB & CHANNEL CONCRETE SHALL HAVE
A CEMENT CONTENT OF AT LEAST 320kg/m³.

NOTES:

1. GENERALLY TO BE USED IN MAJOR RE-INSTATEMENT WORKS
2. REQUIRES APPROVAL BY COUNCIL HERITAGE OFFICER IN HERITAGE DESIGNATED AREAS.

VER	APPD.	DATE	AMENDMENT
1		OCT 08	CEMENT CONTENT ADDED
0		APR 08	REVISED AND REISSUED

REFERENCES:

APPROVED:
D Hannah
Manager Engineering Services
Date: April 2008



STANDARD DETAIL
BLUESTONE KERB & CONCRETE CHANNEL
(MAJOR WORKS)

DRAWING No:
CGG416

AMENDMENT:
1